

From:
Sent:
To:
Cc:
Subject: RE: DRP Follow-up

Warning: This email generated from an external sender!
DO NOT CLICK links if the sender is unknown, and **NEVER** provide your password.

As we continue to work toward a better plan for economic empowerment for the Chiller Plant project, I wanted to address two concerns that were raised during our follow up meeting with the DRP relating to noise and water treatment. Here is the information that addresses those issues:

Potential noise related to frequency vs. Db

Low-frequency noise is not expected to create any health concerns in the area. There are no peer reviewed studies proving a link between low-frequency noise and health issues. Low frequency noise is known to cause vibrations within the Chiller Plant which can be considered annoying for the occupants of the Plant itself. ANSI 12.2-2008, provides sound levels that are considered clearly / moderately perceptible and vibrations in lightweight structures are likely / possible for 16, 31.5, and 63 Hz. Each piece of equipment will emit sounds at different Mhz. The sound profiles of our equipment does not include each of these frequencies.

Water Treatment

Pitt performs chemical water treatment on our Chiller Plant water and do weekly water tests. We utilize a Bromine water treatment for our cooling towers and perform semi-annual legionella testing on all Cooling Towers. The water used in the chiller plant is a closed loop system, protected against backflow.

When we have our revised MBE plan, we will reach out for another opportunity to improve our score with the DRP and review the plan.

Thanks,